

Aço inoxidável de grau marinho Duplex 2205 Montagem da base Torneira de vidro quadrada Padrão australiano para cerca de vidro sem moldura.

Características -

- Modelo No. SBM
- Material - duplex 2205, SS 316, SS316L, SS304
- Acabamento - cetim, espelho, preto, ouro, branco etc.
- Altura 168 mm
- Tampa da base, inserção de plástico, parafusos ajustáveis incluídos
- 1 pc embalado em uma caixa branca;12 pcs em uma caixa

Galerias de fotos -





KEBIL 科比奥®







Desenhando-



深圳市朗馳商貿有限公司 SHENZHEN LAUNCH CO., LTD.			Surface treatment		Proportio
Design	Jacky	Drawing NO: SHM	Material	2205	1:1
Check		Name:	No note of entity size tolerance		
Craft		Revision	Linear tolerance	X ±0.1	
Audit			tolerance	XX ±0.1	
			Angle	XX ±1°	

Relatório de teste de material Duplex 2205-



12/16/2020 5:54:18 PM

Method: Fe-30
Comment: Cr-, Cr/Ni-steel
Type Standard 18--8

Type corr.concentr.

12/16/2020 5:54:09 PM

Sample Name:

Sample ID:

	C	Si	Mn	P	S	Cr	Mo	Ni
	%	%	%	%	%	%	%	%
< x > (1)	0.0224	0.8873	1.1010	0.0263	0.0032	21.6796	3.0718	5.5691

	Al	Co	Cu	Nb	Ti	V	W	Pb
	%	%	%	%	%	%	%	%
< x > (1)	< 0.0005	0.0797	0.1603	< 0.0002	0.0044	0.0893	0.0305	< 0.0002

	Sn	Sb	B	N	Fe			
	%	%	%	%	%			
< x > (1)	0.0092	< 0.0004	0.0024	0.1024	67.1600			

SBM cor pretavidrotorneiras

Model : SBM



MATT BLACK ELECTRO PLATING



MATT BLACK ELECTRO PLATING PROCESS

LOADING TEST FOR SBM

Introduction

MTS Metallurgical Testing Services was engaged to witness the installation of a sample pool fence spigot and to subsequently conduct load tests on the spigot to the requirements of Australian Standard AS1926.1 - 2012.

Standard/Specification AS 1926.1 - 2012, Section 3.2 and Appendix B

Results Summary

(For details of individual tests, refer to the tables on the following pages.)

ID	Item/Item No.	Dimensions/Type/Details	Finish	Overall Assessment
14117/01	SSBM316	60mm Square, Base Plate 316 Stainless steel	316i	COMPLIES

Remarks

After completion of the testing, the spigot was found to be in sound condition with no breakage, tearing or signs of fracture and no looseness of the fixings.



Colin Cummins
Metallurgical Testing Manager



Accreditation No: 15624
Accredited for compliance
with ISO/IEC 17025

Strength Test

Test Specification AS 1926.1 - 2012, Appendix B Test Procedure MTS-TP3.1 Compression Tests - Products


Specimen ID	Observations	Assessment
14117/01	Test Equipment: Hydraulic ram and 10,000 N load cell Test Load: 330N Load Duration: 45 Secs Deflection under load: 1 mm Permanent Deflection after removal of test load: 0 mm	COMPLIES


Requirements No permanent damage or loosening of fixings.

Galários de projeto para torneira de vidro quadrada de montagem de base, SBM-









SHENZHEN LAUNCH CO., LTD

